



# UL Online Certifications Directory

[Home](#) [Quick Guide](#) [Contact Us](#) [UL.com](#)

## VFXT.EX2709 Hangers, Pipe

[Page Bottom](#)

### Hangers, Pipe

[See General Information for Hangers, Pipe](#)

#### HILTI INC

EX2709

7250 Dallas Pky , Legacy Tower Suite 1000

Plano, TX 75024 USA

Model Designation	Hanger Type	Rod Size	Nominal Pipe Size	Comments
00257366	Universal Beam Clamp	3/8 in.	Up to 4	-
00257367	Universal Beam Clamp	1/2 in.	Up to 8	-
00257368	Universal Beam Clamp	5/8 in.	Up to 10	-
00257369	Universal Beam Clamp	3/4 in.	Up to 12	-
00306600	Universal Beam Clamp	3/8 in.	Up to 4	-
00306601	Universal Beam Clamp	1/2 in.	Up to 8	-
00306602	Universal Beam Clamp	3/8 in.	Up to 4	-
00306603	Universal Beam Clamp	1/2 in.	Up to 8	-
BC	Universal Beam Clamp	3/4 in.	Up to 10	-

<b>BC</b>	Universal Beam Clamp	5/8 in.	Up to 10	-
<b>BC</b>	Universal Beam Clamp	1/2 in.	Up to 8	-
<b>ES</b>	Eyelet	3/8 in.	Up to 4	-
<b>HCI-MD</b>	Cast-in-place Concrete Insert	3/4 in.	12	Intended for use in concrete w/ a minimum compressive strength of 3000 psi. Also suitable for air-handling spaces.
<b>HCI-MD</b>	Cast-in-place Concrete Insert	5/8 in.	Up to 12	Intended for use in concrete w/ a minimum compressive strength of 3000 psi. Also suitable for air-handling spaces.
<b>HCI-MD</b>	Cast-in-place Concrete Insert	3/8 in.	Up to 4	Intended for use in concrete w/ a minimum compressive strength of 3000 psi. Also suitable for air-handling spaces.
<b>HCI-MD</b>	Cast-in-place Concrete Insert	1/2 in.	Up to 8	Intended for use in concrete w/ a minimum compressive strength of 3000 psi. Also suitable for air-handling spaces.
<b>HCI-WF</b>	Cast-in-place Concrete Insert	3/8 in.	Up to 4	Intended for use in concrete w/ a minimum compressive strength of 3000 psi. Also suitable for air-handling spaces.
<b>HCI-WF</b>	Cast-in-place Concrete Insert	3/4 in.	Up to 8	Intended for use in concrete w/ a minimum compressive strength of 3000 psi. Also suitable for air-handling spaces.
<b>HCI-WF</b>	Cast-in-place Concrete Insert	5/8 in.	Up to 8	Intended for use in concrete w/ a minimum compressive strength of 3000 psi. Also suitable for air-handling spaces.
<b>HCI-WF</b>	Cast-in-place Concrete Insert	1/2 in., 5/8 in., 3/4 in.	Up to 8	Intended for use in concrete w/ a minimum compressive strength of 3000 psi. Also suitable for air-handling spaces.
<b>HDI 1/2</b>	Drop-In Anchor	1/2 in.	Up to 8	-
<b>HDI 3/4</b>	Drop-In Anchor	3/4 in.	12	-

<b>HDI 3/8</b>	Drop-In Anchor	3/8 in.	Up to 4	-
<b>HDI 5/8</b>	Drop-In Anchor	5/8 in.	10, 12	-
<b>HDI+</b>	Drop-In Anchor	3/8 in.	Up to 4	-
<b>HDI+</b>	Drop-In Anchor	1/2 in.	Up to 8	-
<b>HDI-L 1/2</b>	Drop-In Anchor	1/2 in.	Up to 8	-
<b>HDI-L 3/8</b>	Drop-In Anchor	3/8 in.	Up to 4	-
<b>HDI-L+</b>	Drop-In Anchor	3/8 in.	Up to 4	-
<b>HDI-L+</b>	Drop-In Anchor	1/2 in.	Up to 8	-
<b>HDV 1/2</b>	Drop-In Anchor	1/2 in.	Up to 8	-
<b>HDV 3/8</b>	Drop-In Anchor	3/8 in.	Up to 4	-
<b>KB-VTZ 1/2</b>	Expansion Anchor	1/2 in.	Up to 8	-
<b>KB-VTZ 3/4</b>	Expansion Anchor	3/4 in.	Up to 12	-
<b>KB-VTZ 3/8</b>	Expansion Anchor	3/8 in.	Up to 4	-
<b>KB-VTZ 5/8</b>	Expansion Anchor	5/8 in.	Up to 10	4-3/4 and 6 inch anchor length with minimum 3-5/16 in. nominal embedment depth.
<b>KB-VTZ 5/8</b>	Expansion Anchor	5/8 in.	Up to 12	6 inch anchor length with minimum 4-9/16 in. nominal embedment depth.
<b>KBV 1/2</b>	Expansion Anchor	1/2 in.	5, 6, 7, 8	-
<b>KBV 3/4</b>	Expansion Anchor	3/4 in.	12	-
<b>KBV 3/8</b>	Expansion	3/8 in.	Up to 4	-

	Anchor			
<b>KBV 5/8</b>	Expansion Anchor	5/8 in.	10, 12	-
<b>KCS-MD</b>	Cast-in-place Concrete Insert	5/8 in.	Up to 12	Intended for use in concrete w/ a minimum compressive strength of 3000 psi. Also suitable for air-handling spaces.
<b>KCS-MD</b>	Cast-in-place Concrete Insert	3/4 in.	12	Intended for use in concrete w/ a minimum compressive strength of 3000 psi. Also suitable for air-handling spaces.
<b>KCS-MD</b>	Cast-in-place Concrete Insert	3/8 in.	Up to 4	Intended for use in concrete w/ a minimum compressive strength of 3000 psi. Also suitable for air-handling spaces.
<b>KCS-MD</b>	Cast-in-place Concrete Insert	1/2 in.	Up to 8	Intended for use in concrete w/ a minimum compressive strength of 3000 psi. Also suitable for air-handling spaces.
<b>KCS-WF</b>	Cast-in-place Concrete Insert	3/8 in.	Up to 4	Intended for use in concrete w/ a minimum compressive strength of 3000 psi. Also suitable for air-handling spaces.
<b>KCS-WF</b>	Cast-in-place Concrete Insert	5/8 in.	Up to 8	Intended for use in concrete w/ a minimum compressive strength of 3000 psi. Also suitable for air-handling spaces.
<b>KCS-WF</b>	Cast-in-place Concrete Insert	1/2 in.	Up to 8	Intended for use in concrete w/ a minimum compressive strength of 3000 psi. Also suitable for air-handling spaces.
<b>KCS-WF</b>	Cast-in-place Concrete Insert	3/4 in.	Up to 8	Intended for use in concrete w/ a minimum compressive strength of 3000 psi. Also suitable for air-handling spaces.
<b>Kwik Bolt 3 1/2</b>	Expansion Anchor	1/2 in.	5, 6, 7, 8	-
<b>Kwik Bolt 3 3/4</b>	Expansion Anchor	3/4 in.	12	-
<b>Kwik Bolt 3 3/8</b>	Expansion Anchor	3/8 in.	Up to 4	-

<b>Kwik Bolt 3/8</b>	Expansion Anchor	5/8 in.	10, 12	-
<b>Kwik Bolt TZ 1/2</b>	Expansion Anchor	1/2 in.	5, 6, 7, 8	-
<b>Kwik Bolt TZ 3/4</b>	Expansion Anchor	3/4 in.	12	-
<b>Kwik Bolt TZ 3/8</b>	Expansion Anchor	3/8 in.	Up to 4	-
<b>Kwik Bolt TZ 5/8</b>	Expansion Anchor	5/8 in.	10, 12	-
<b>LH</b>	Band Hanger	1/2 in.	8	EG (electro-galvanized), HD (felt-lined over EG), FL (hot-dipped)
<b>MF-TSH</b>	Trapezoidal Bracket	10 mm	3/4, 1	-
<b>MP-MS</b>	Pipe Clamp	10 mm	1/2, 3/4, 1, 1-1/4, 1-1/2, 2, 2-1/2, 3	-
<b>MP-MS</b>	Pipe Clamp	12 mm	4, 5, 6	-
<b>MP-SP</b>	Band Hanger	10 mm	Up to 4	-
<b>MP-SP</b>	Band Hanger	12 mm	5, 6	-
<b>MP-SP</b>	Band Hanger	16 mm	8	-
<b>OES</b>	Offset Eyelet	3/8 in.	Up to 4	-
<b>SDC-EG</b>	Clevis Hanger	1/2 in.	2-1/2, 3, 3-1/2	-
<b>SDC-EG</b>	Clevis Hanger	5/8 in.	4, 5	-
<b>SDC-EG</b>	Clevis Hanger	3/4 in.	6, 8	-

[Last Updated](#) on 2016-12-19

[Questions?](#)

[Print this page](#)

[Terms of Use](#)

[Page Top](#)

© 2016 UL LLC

The appearance of a company's name or product in this database does not in itself assure that products so identified have been manufactured under UL's Follow-Up Service. Only those products bearing the UL Mark should be considered to be Certified and covered under UL's Follow-Up Service. Always look for the Mark on the product.

UL permits the reproduction of the material contained in the Online Certification Directory subject to

the following conditions: 1. The Guide Information, Assemblies, Constructions, Designs, Systems, and/or Certifications (files) must be presented in their entirety and in a non-misleading manner, without any manipulation of the data (or drawings). 2. The statement "Reprinted from the Online Certifications Directory with permission from UL" must appear adjacent to the extracted material. In addition, the reprinted material must include a copyright notice in the following format: "© 2016 UL LLC".