



Classified by
Underwriters Laboratories, Inc.
to UL 1479


System No. C-AJ-2565

F Rating - 2 Hr

T Rating - 0 Hr

W Rating - Class 1 (See Item 2)

CAJ 2565



SECTION A-A



Hilti Firestop Systems

Reproduced by HILTI, Inc. Courtesy of
Underwriters Laboratories, Inc.
February 17, 2022

System No. C-AJ-2565

CAJ 2565

1. Floor or Wall Assembly — Min 4-1/2 in. (114 mm) thick reinforced lightweight or normal weight (100-150 pcf or 1600-2400 kg/m³) concrete floor or wall. Wall may also be constructed of any UL Classified Concrete Blocks*. Max diam of opening is 6 in. (152 mm).
See Concrete Blocks (CAZT) category in the Fire Resistance Directory for names of manufacturers.
2. Through Penetrants — One nonmetallic pipe to be installed concentrically or eccentrically within the firestop system. Annular space within the firestop system is dependent upon the max diam and type of penetrant used as tabulated in Item 3A. Pipe to be rigidly supported on both sides of floor or wall assembly. The following types and sizes of nonmetallic pipes may be used:
 - A. Polyvinyl Chloride (PVC) Pipe — Nom 4 in. (102 mm) diam (or smaller) Schedule 40 solid or cellular core PVC for use in closed (process or supply) or vented (drain, waste or vent) piping systems.
 - B. Rigid Nonmetallic Conduit+ — Nom 4 in. (102 mm) diam (or smaller) Schedule 40 PVC conduit installed in accordance with Article 347 of the National Electrical Code (NFPA 70).
 - C. Acrylonitrile Butadiene Styrene (ABS) Pipe — Nom 4 in. (102 mm) diam (or smaller) Schedule 40 solid or cellular core ABS for use in closed (process or supply) or vented (drain, waste or vent) piping systems.
 - D. Flame Retardant Polypropylene (FRPP) Pipe — Nom 4 in. (102 mm) diam (or smaller) Schedule 40 FRPP pipe for use in closed (process or supply) or vented (drain, waste or vent) piping system.

W Rating applies to nom 1-1/2 in. diam penetrants only.
3. Firestop System — The firestop system shall consist of the following:
 - A. Fill, Void or Cavity Material* - Wrap Strip — One layer of intumescent wrap strip is continuously wrapped around the pipe with ends butted and held in place with integrated tape. Wrap strip installed recessed max 1-1/4 in. (32 mm) from bottom surface of floor or min 1 in. (25 mm) from both surfaces of wall. Size of wrap strip for a given size penetrant is shown in the table below.
HILTI CONSTRUCTION CHEMICALS, DIV OF HILTI INC — CP648-S-1.5" US, CP648-S-2" US, CP648-S-3" US or CP648-S-4" US Wrap Strip

Product Designation	Pipe Size in. (mm)	Max Opening Diam in. (mm)	Annular Space Min in. (mm)	Annular Space Max in. (mm)	Nom Wrap Strip Length in. (mm)	Nom Wrap Strip Thick in. (mm)	Nom Wrap Strip Width in. (mm)
CP648-S-1.5" US	1-1/2 (38)	3 (76)	3/16 (5)	3/4 (19)	6.5 (165)	0.18 (5)	1 (25)
CP648-S-2" US	2 (51)	3-1/2 (89)	3/16 (5)	15/16 (24)	8 (203)	0.18 (5)	1 (25)
CP648-S-3" US	3 (76)	4 (102)	3/16 (5)	15/16 (24)	11.5 (292)	0.18 (5)	1-3/4 (44)
CP648-S-4" US	4 (102)	6 (152)	3/8 (5)	1-1/8 (28)	15.1 (384)	0.36 (9)	1-3/4 (44)

- B. Fill, Void or Cavity Material* - Foam — Min 1 in. (25 mm) thickness of fill material applied within the annulus, flush with top surface of floor or with both surfaces of wall.
HILTI CONSTRUCTION CHEMICALS, DIV OF HILTI INC — CP620 Fire Foam

* Indicates such products shall bear the UL or cUL Certification Mark for jurisdictions employing the UL or cUL Certification (such as Canada), respectively.



Reproduced by HILTI, Inc. Courtesy of
Underwriters Laboratories, Inc.
February 17, 2022