


System No. W-L-2480

F Ratings — 1 and 2 Hr (See Item 1) T Rating — 0 Hr



- 1. Wall Assembly The 1 or 2 hr fire rated gypsum board/stud wall assembly shall be constructed of the materials and in the manner specified in the individual U300, U400, V400 or W400 Series Wall and Partition Designs in the UL Fire Resistance Directory and shall include the following construction features:
 - A. Studs Wall framing may consist of either wood studs or steel channel studs. Wood studs to consist of nom 2 by 4 in. (51 by 102 mm) lumber spaced max 16 in. (406 mm) OC. Steel studs to be min 3-1/2 in. (89 mm) wide and spaced max 24 in. (610 mm) OC.
 - B. Gypsum Board* One or two layers of gypsum board, as specified in the individual Wall and Partition Design. Max area of opening 17 in. (110 cm2) with a max dimension of 8-1/2 in. (102 mm).
 - The hourly F Rating of the firestop system is equal to the hourly rating of the wall assembly in which it is installed.
- 2. Crosslinked Polyethylene (PEX) Tubing Max six nom 1 in. (25 mm) diam (or smaller) SDR 9 PEX tubing for use in closed (process or supply) piping systems, installed either concentrically or eccentrically within the firestop system. The annular space between the tubing and the edge of the opening shall be min 1/4 in. (6 mm) to max 1 in. (25 mm). Separation between tubes shall be min 1/4 in. (6 mm). Tubing to be rigidly supported on both sides of wall assembly.
- 3. Fill, Void or Cavity Materials* Sealant Min 5/8 in. (16 mm) thickness of thickness of sealant applied within annular space, flush with both surfaces of wall.
- HILTI CONSTRUCTION CHEMICALS, DIV OF HILTI INC FS-ONE Sealant or FS-ONE MAX Intumescent Sealant
- * Indicates such products shall bear the UL or cUL Certification Mark for jurisdictions employing the UL or cUL Certification (such as Canada), respectively.

